



REPORT OF ANALYSIS

ATTENTION: Don M. Gregoire
 COMPANY: Virgin Islands Water & Power Authority
 PO Box 1450 St. Thomas, VI 00804

DATE: October 24, 2023

CONTRACT: Virgin Islands Water & Power Authority

PWSS# VI0000097

LAB. SAMPLE ID: BEL-2304408
 SAMPLE COLLECTED BY: Michael Diaz (Client)
 SAMPLE RECEIVED: 10/19/23
 MATRIX: Drinking Water

DESCRIPTION: PWS ID: VI0000097
 Woodson Jr. High-Kitchen Sink (001)
 SAMPLE DATE: 10/19/23
 SAMPLE TIME: 9:27AM
 LAB. FILE ID: 2304408

PARAMETER	METHOD	SAMPLE TYPE	UNITS	BEL-2304408 RESULTS	MRL	MCL	ANALYST	DATE ANALYZED
COPPER	EPA 200.7(ICAP)	Grab	mg/L	0.002	0.002**	1.30	BTR	10/23/23
LEAD ^A	EPA 200.8	Grab	mg/L	0.00172	0.00100*	0.015	CRP ^A	10/24/23

LAB. SAMPLE ID: BEL-2304409
 SAMPLE COLLECTED BY: Michael Diaz (Client)
 SAMPLE RECEIVED: 10/19/23
 MATRIX: Drinking Water

DESCRIPTION: PWS ID: VI0000097
 Woodson Jr. High-Kitchen Sink (002)
 SAMPLE DATE: 10/19/23
 SAMPLE TIME: 9:40AM

PARAMETER	METHOD	SAMPLE TYPE	UNITS	BEL-2304409 RESULTS	MRL	MCL	ANALYST	DATE ANALYZED
COPPER	EPA 200.7(ICAP)	Grab	mg/L	0.005	0.002**	1.30	BTR	10/23/23
LEAD ^A	EPA 200.8	Grab	mg/L	<0.00100	0.00100*	0.015	CRP ^A	10/24/23

LAB. SAMPLE ID: BEL-2304410
 SAMPLE COLLECTED BY: Michael Diaz (Client)
 SAMPLE RECEIVED: 10/19/23
 MATRIX: Drinking Water

DESCRIPTION: PWS ID: VI0000097
 Woodson Jr. High-Bathroom (003)
 SAMPLE DATE: 10/19/23
 SAMPLE TIME: 9:51

PARAMETER	METHOD	SAMPLE TYPE	UNITS	BEL-2304410 RESULTS	MRL	MCL	ANALYST	DATE ANALYZED
COPPER	EPA 200.7(ICAP)	Grab	mg/L	0.003	0.002**	1.30	BTR	10/23/23
LEAD ^A	EPA 200.8	Grab	mg/L	<0.00100	0.00100*	0.015	CRP ^A	10/24/23

LAB. SAMPLE ID: BEL-2304411
 SAMPLE COLLECTED BY: Michael Diaz (Client)
 SAMPLE RECEIVED: 10/19/23
 MATRIX: Drinking Water

DESCRIPTION: PWS ID: VI0000097
 Alfredo Andrew-Kitchen Sink (004)
 SAMPLE DATE: 10/19/23
 SAMPLE TIME: 10:17AM

PARAMETER	METHOD	SAMPLE TYPE	UNITS	BEL-2304411 RESULTS	MRL	MCL	ANALYST	DATE ANALYZED
COPPER	EPA 200.7(ICAP)	Grab	mg/L	0.536	0.002**	1.30	BTR	10/23/23
LEAD ^A	EPA 200.8	Grab	mg/L	0.00749	0.00100*	0.015	CRP ^A	10/24/23

Handwritten initials

REPORT OF ANALYSIS
PAGE 2 OF 3

LAB. SAMPLE ID: BEL-2304408 TO BEL-2304417

LAB. SAMPLE ID: BEL-2304412
 SAMPLE COLLECTED BY: Michael Diaz (Client)
 SAMPLE RECEIVED: 10/19/23
 MATRIX: Drinking Water

DESCRIPTION: PWS ID: VI0000097
 Alfredo Andrew-Kitchen Sink (005)
 SAMPLE DATE: 10/19/23
 SAMPLE TIME: 10:30

PARAMETER	METHOD	SAMPLE TYPE	UNITS	BEL-2304412 RESULTS	MRL	MCL	ANALYST	DATE ANALYZED
COPPER	EPA 200.7(ICAP)	Grab	mg/L	0.009	0.002**	1.30	BTR	10/23/23
LEAD [^]	EPA 200.8	Grab	mg/L	<0.00100	0.00100*	0.015	CRP [^]	10/24/23

LAB. SAMPLE ID: BEL-2304413
 SAMPLE COLLECTED BY: Michael Diaz (Client)
 SAMPLE RECEIVED: 10/19/23
 MATRIX: Drinking Water

DESCRIPTION: PWS ID: VI0000097
 Mount Pleasant-Bathroom (006)
 SAMPLE DATE: 10/19/23
 SAMPLE TIME: 12:26

PARAMETER	METHOD	SAMPLE TYPE	UNITS	BEL-2304413 RESULTS	MRL	MCL	ANALYST	DATE ANALYZED
COPPER	EPA 200.7(ICAP)	Grab	mg/L	0.014	0.002**	1.30	BTR	10/23/23
LEAD [^]	EPA 200.8	Grab	mg/L	0.00469	0.00100*	0.015	CRP [^]	10/24/23

LAB. SAMPLE ID: BEL-2304414
 SAMPLE COLLECTED BY: Michael Diaz(Client)
 SAMPLE RECEIVED: 10/19/23
 MATRIX: Drinking Water

DESCRIPTION: PWS ID:VI0000097
 Mount Pleasant-Bathroom (007)
 SAMPLE DATE: 10/19/23
 SAMPLE TIME: 12:41

PARAMETER	METHOD	SAMPLE TYPE	UNITS	BEL-2304414 RESULTS	MRL	MCL	ANALYST	DATE ANALYZED
COPPER	EPA 200.7(ICAP)	Grab	mg/L	<0.002	0.002**	1.30	BTR	10/23/23
LEAD [^]	EPA 200.8	Grab	mg/L	<0.00100	0.00100*	0.015	CRP [^]	10/24/23

LAB. SAMPLE ID: BEL-2304415
 SAMPLE COLLECTED BY: Michael Diaz (Client)
 SAMPLE RECEIVED: 10/19/23
 MATRIX: Drinking Water

DESCRIPTION: PWS ID: VI0000097
 C-Tech-Culinary Art H III (008)
 SAMPLE DATE: 10/19/23
 SAMPLE TIME: 13:37

PARAMETER	METHOD	SAMPLE TYPE	UNITS	BEL-2304415 RESULTS	MRL	MCL	ANALYST	DATE ANALYZED
COPPER	EPA 200.7(ICAP)	Grab	mg/L	0.006	0.002**	1.30	BTR	10/23/23
LEAD [^]	EPA 200.8	Grab	mg/L	<0.00100	0.00100*	0.015	CRP [^]	10/24/23

LAB. SAMPLE ID: BEL-2304416
 SAMPLE COLLECTED BY: Michael Diaz (Client)
 SAMPLE RECEIVED: 10/19/23
 MATRIX: Drinking Water

DESCRIPTION: PWS ID: VI0000097
 G-Tech-Auto Body (009)
 SAMPLE DATE: 10/19/23
 SAMPLE TIME: 13:59

PARAMETER	METHOD	SAMPLE TYPE	UNITS	BEL-2304416 RESULTS	MRL	MCL	ANALYST	DATE ANALYZED
COPPER	EPA 200.7(ICAP)	Grab	mg/L	0.085	0.002**	1.30	BTR	10/23/23
LEAD [^]	EPA 200.8	Grab	mg/L	<0.00100	0.00100*	0.015	CRP [^]	10/24/23

Handwritten signature

REPORT OF ANALYSIS
PAGE 3 OF 3

LAB. SAMPLE ID: BEL-2304408 TO BEL-2304417

LAB. SAMPLE ID: BEL-2304417
 SAMPLE COLLECTED BY: Randa Desuza (Client)
 SAMPLE RECEIVED: 10/19/23
 MATRIX: Drinking Water

DESCRIPTION: PWS ID: VI0000097
 #51-Rickmond Entry (010)
 SAMPLE DATE: 10/19/23
 SAMPLE TIME: 15:25

PARAMETER	METHOD	SAMPLE TYPE	UNITS	BEL-2304417 RESULTS	MRL	MCL	ANALYST	DATE ANALYZED
COPPER	EPA 200.7(ICAP)	Grab	mg/L	0.021	0.002**	1.30	BTR	10/23/23
LEAD ^A	EPA 200.8	Grab	mg/L	0.00294	0.00100*	0.015	CRP ^A	10/24/23

Notes: "The PRDOH's manual for the certification of Laboratories analyzing Drinking Water (PRDOH-016-8-90) requires that those who collect drinking water sample must be trained and certified to do so." PRDOH-016-8-90 Section 3.3. The samples were collected by a sample collector with no certification by Puerto Rico Department of Health.

^AAnalysis performed by Environmental Quality Laboratories, Inc. This laboratory is certified by the Puerto Rico Department of Health for Drinking Water Analysis with EPA ID: PR00014.

Beckton Laboratory Inc. is certified by the Puerto Rico Department of Health for Drinking Water Analysis with EPA ID: PR00012.
 Drinking Water laboratory is certified by local authorities, not by NELAC.

The method detection limit (MDL) is defined as the minimum concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results.


MCL: Maximum Contamination Level

*MRL (Minimum Reporting Limit) – Is the lowest concentration at which an analyte can be detected in a sample and its concentration can be reported with reasonable degree of accuracy and precision.

**Method Detection Limit (Beckton Environmental Laboratories analysis)

Certification and release of the data contained in the Report of Analysis has been authorized by the Laboratory Manager or the Manager's Designee. Sample results related only to the sample submitted. This report shall not be reproduced except in full, without written approval from Beckton Environmental Laboratories, Inc.

Heidy E. Alfonso Rivera
 Lcdá. Heidy E. Alfonso Rivera
 Laboratory Director
 Chemist License 4120



Attachment: Chain of Custody Record (10) and EQLAB Report



192 Villa Street
 Ponce, Puerto Rico 00730-4875
 Tel. 787-841-7373 Fax 787-841-7313
 Lab ID #: PR00012

Control Number
 149851

Chain of Custody - Drinking Water

COMPANY VIWAPA-STX		SAMPLER NAME: Michael Diaz		ID # Collector:
SYSTEM NAME IDENTIFICATION: PIPS ID: VI-0000917		SAMPLER SIGNATURE: <i>Michael Diaz</i>		
SYSTEM ID: VI-0000917	STATION NUMBER	SAMPLING DATE	SAMPLING TIME	SAMPLING LOCATION: WOODSON SR. HIGH - HIGHWAY SINK
		10/19/2023	9:27	TYPE OF SAMPLE DRINKING WATER
CONDUCTIVITY 593 μ mhos/cm	DISSOLVED OXYGEN N/A mg/L	PH 8.2 S.U.	Temperature 32 °C	Residual chloride 0.71 mg/L
Parameters to be tested: CAD COPPER		Preservatives N/A N/A		Container (size/type/volume) 1 LITER 1 LITER
Sampling witness: <i>John E. Ash</i>		Date / Time: 10/19/23 9:27		Temperature Received:
Relinquished by: <i>Don Gregoire</i>		Date/ Time: 10/19/23 @ 3:50 pm		Date/ Time: 10-19-23 @ 3:50 pm
Relinquished by: <i>Don Gregoire</i>		Date/ Time: 10-20-23 9:35 am		Date/ Time: 10-20-23 9:36 am

ORIGINAL

REVISION: 06/2023



192 Villa Street
 Ponce, Puerto Rico 00730-4875
 Tel. 787-841-7373 Fax 787-841-7313
 Lab ID #: PR00012

Control Number
 149852

Chain of Custody - Drinking Water

COMPANY <i>VI WAPA-STX</i>		SAMPLER NAME: <i>Michael Diaz</i>		ID # Collector:
SYSTEM NAME IDENTIFICATION: SIS ID: <i>VI000097</i>		SAMPLER SIGNATURE: <i>Michael Diaz</i>		
SYSTEM ID: PWSS#	STATION NUMBER	SAMPLING DATE	SAMPLING TIME	WATER SOURCE
<i>VI000097</i>	<i>N/A</i>	<i>10/19/23</i>	<i>9:40</i>	<i>DRINKING WATER BEAB</i>
CONDUCTIVITY	DISSOLVED OXYGEN	PH	TEMPERATURE	RESIDUAL CHLORIDE
<i>593</i> umhos/cm	<i>N/A</i> mg/L	<i>8.2</i> S.U.	<i>32</i> °C	<i>0.71</i> mg/L
Parameters to be tested:		Preservatives		Container (size/type/volume)
<i>LEAD</i>		<i>N/A</i>		<i>1 LITER</i>
<i>LEAD</i>		<i>N/A</i>		<i>1 LITER</i>
Sampling witness: <i>DM</i>		Date / Time: <i>10/19/23 9:40</i>		Temperature Received:
Relinquished by: <i>John E. L.</i>		Date / Time: <i>10/19/23 @ 3:50pm</i>		Date / Time: <i>10-19-23 @ 3:50 PM</i>
Relinquished by: <i>Don Gregoire</i>		Date / Time: <i>10-20-23 9:35 am</i>		Date / Time: <i>10-20-23 9:36 AM</i>

ORIGINAL

REVISION: 06/2023



192 Villa Street
 Ponce, Puerto Rico 00730-4875
 Tel. 787-841-7373 Fax 787-841-7313
 Lab ID #: PR00012

Control Number
 149854

Chain of Custody - Drinking Water

COMPANY <i>VI WAPA - ST4</i>		SAMPLER NAME: <i>Michael Diaz</i>		ID # Collector:
SYSTEM NAME IDENTIFICATION: <i>PWS ID: VI 0000097</i>		SAMPLER SIGNATURE: <i>Michael Diaz</i>		
SAMPLING LOCATION: <i>ALFREDO ANDREW - KITCHEN SINK</i>				
SYSTEM ID: PWSS#	STATION NUMBER	SAMPLING DATE	SAMPLING TIME	WATER SOURCE
<i>VI 0000097</i>	<i>N/A</i>	<i>10/19/2023</i>	<i>10:17 AM</i>	<i>DRINKING WATER</i>
CONDUCTIVITY umhos/cm	DISSOLVED OXYGEN mg/L	PH	TEMPERATURE °C	RESIDUAL CHLORIDE mg/L
	<i>N/A</i>	<i>7.8</i>	<i>32</i>	<i>0.07</i>
Parameters to be tested:		Container (size/type/volume)		
<i>Lead</i>	<i>N/A</i>	<i>1 liter</i>		
<i>Copper</i>	<i>N/A</i>	<i>1 liter</i>		
Sampling witness: <i>DK</i>		Date / Time: <i>10/19/23 10:17</i>		Temperature Received:
Relinquished by: <i>Don E. Auk</i>	Date/Time: <i>10/19/23 @ 3:50 pm</i>	Received by: <i>Don Gregoire</i>		Date/Time: <i>10-19-23 @ 3:50 pm</i>
Relinquished by: <i>Don Gregoire</i>	Date/Time: <i>10-20-23 9:35 am</i>	Received by: <i>DK</i>		Date/Time: <i>10-20-23 9:36 am</i>

REVISION: 06/2023

ORIGINAL

Control Number
149855



192 Villa Street
Ponce, Puerto Rico 00730-4875
Tel. 787-841-7373 Fax 787-841-7313
Lab ID #: PR00012

Chain of Custody - Drinking Water

COMPANY: VIPAA-STX		SAMPLER NAME: Michael Diaz		ID # Collector:	
SYSTEM NAME IDENTIFICATION:		SAMPLER SIGNATURE: <i>Michael Diaz</i>			
SYSTEM ID: 15000091		SAMPLING LOCATION: ALFREDO ANDRUEW - KITCHEN SINK		SAMPLE NUMBER	
PWSS#		WATER SOURCE		TYPE OF SAMPLE	
STATION NUMBER: N/A		SAMPLING TIME: 10:30		SAMPLE NUMBER: 005	
SAMPLING DATE: 10/19/2023		DRINKING WATER		Residual chloride	
DISSOLVED OXYGEN		Temperature: 32 °C		mg/L	
CONDUCTIVITY: 594 μ mhos/cm		PH: 7.8 S.U.			
Parameters to be tested:		Container (size/type/volume)			
LEAD		1.9 L LITER			
COPPER		1 L LITER			
Sampling witness: <i>[Signature]</i>		Date / Time: 10/19/23 10:30		Temperature Received:	
Relinquished by: <i>[Signature]</i>		Date/Time: 10/14/23 @ 3:50 pm		Date/Time: 10-19-23 @ 3:50 pm	
Relinquished by: <i>Don Gregoire</i>		Date/Time: 10-20-23 9:35 am		Date/Time: 10-20-23 9:36 am	

REVISION: 06/2023

ORIGINAL

Control Number
149856



192 Villa Street
Ponce, Puerto Rico 00730-4875
Tel. 787-841-7373 Fax 787-841-7313
Lab ID #: PR00012

Chain of Custody - Drinking Water

COMPANY <i>VI WAPA - ST 4</i>		SAMPLER NAME: <i>Michael Diaz</i>		ID # Collector
SYSTEM NAME IDENTIFICATION: <i>INS ID: VI-000097</i>		SAMPLER SIGNATURE: <i>Michael Diaz</i>		
SAMPLING LOCATION: <i>MOUNT PLEASANT - BATHROOM</i>		WATER SOURCE		SAMPLE NUMBER
SYSTEM ID: PWSS#	STATION NUMBER	SAMPLING DATE	SAMPLING TIME	TYPE OF SAMPLE
<i>VI-000097</i>	<i>N/A</i>	<i>10/19/2023</i>	<i>12:26</i>	<i>GRAB</i>
CONDUCTIVITY <i>597</i> umhos/cm	DISSOLVED OXYGEN <i>N/A</i> mg/L	PH <i>7.7</i> S.U.	Temperature <i>32</i> °C	Residual chloride <i>1.08</i> mg/L
Parameters to be tested:		Container (size/type/volume)		
<i>LEAD</i>		<i>N/A</i>	<i>1</i>	<i>LITER</i>
<i>COPPER</i>		<i>N/A</i>	<i>1</i>	<i>LITER</i>
Sampling witness: <i>OK</i>		Date / Time: <i>10/19/23 12:26</i>		Temperature Received:
Relinquished by: <i>Don Gregoire</i>	Date/Time: <i>10/19/2023 @ 3:50 pm</i>	Received by: <i>Don Gregoire</i>		Date/Time: <i>10-19-23 3:50 pm</i>
Relinquished by: <i>Don Gregoire</i>	Date/Time: <i>10-20-23 9:35 am</i>	Received by: <i>Ed</i>		Date/Time: <i>10-20-23 9:36 am</i>

REVISION: 06/2023

ORIGINAL



192 Villa Street
 Ponce, Puerto Rico 00730-4875
 Tel. 787-841-7373 Fax 787-841-7313
 Lab ID #: PR00012

Control Number
 149857

Chain of Custody - Drinking Water

COMPANY	VI MAPA-STX		SAMPLER NAME: Michael Diaz	ID # Collector:
SYSTEM NAME IDENTIFICATION:	PWS ID: VI0000097		SAMPLER SIGNATURE: <i>Michael Diaz</i>	
SYSTEM ID: PWS#	STATION NUMBER	SAMPLING DATE	SAMPLING TIME	WATER SOURCE
VI000097	N/A	10/19/2023	12:41	Mount Westside - Bathroom
CONDUCTIVITY	DISSOLVED OXYGEN	PH	Temperature	Residual chloride
umhos/cm	N/A	7.7	32 °C	1.08 mg/L
Parameters to be tested:	Container (size/type/volume)			
LEAD	N/A			
COPPER	N/A			
Sampling witness: <i>Sh</i>	Date / Time: 10/19/23	12:41	Temperature Received:	
Relinquished by: <i>Shirley E. Ad</i>	Date/Time: 10/19/23 @ 3:50 pm	Received by: <i>Don Gregoire</i>		Date/Time: 10-19-23 3:50 pm
Relinquished by: <i>Don Gregoire</i>	Date/Time: 10-20-23	9:35 am	Received by: <i>Ed</i>	Date/Time: 10-20-23 9:36 am

REVISION: 06/2023

ORIGINAL



192 Villa Street
 Ponce, Puerto Rico 00730-4875
 Tel. 787-841-7373 Fax 787-841-7313
 Lab ID #: PR00012

Control Number
 149858

Chain of Custody - Drinking Water

COMPANY <i>VI WAPA - STX</i>		SAMPLER NAME: <i>Michael Diaz</i>		ID # Collector
SYSTEM NAME IDENTIFICATION: <i>PWS ID: VI 000097</i>		SAMPLER SIGNATURE: <i>Michael Diaz</i>		
STATION NUMBER		SAMPLING TIME		SAMPLING LOCATION: <i>P-TECH - CULINARY AREA #111</i>
<i>VI 000097</i>	<i>N/A</i>	<i>10/19/23</i>	<i>13:37</i>	
CONDUCTIVITY	DISSOLVED OXYGEN	PH	TEMPERATURE	RESIDUAL CHLORIDE
<i>596</i> μ mhos/cm	<i>N/A</i> mg/L	<i>8.1</i> S.U.	<i>32</i> °C	<i>1.40</i> mg/L
Parameters to be tested:		Container (size/type/volume)		
<i>LEAD</i>	<i>N/A</i>	<i>↓ LITER</i>		
<i>COPPER</i>	<i>N/A</i>	<i>↓ LITER</i>		
Preservatives		Temperature Received:		
		Date / Time: <i>10/19/23 1:37</i>		
Relinquished by: <i>Shel E. Smith</i>		Date / Time: <i>10/19/23 @ 3:50pm</i>		Date / Time: <i>10-19-23 - 3:50pm</i>
Relinquished by: <i>Don Gregoire</i>		Date / Time: <i>10-20-23 9:35 am</i>		Date / Time: <i>10-20-23 9:36 AM</i>

ORIGINAL

REVISION: 06/2023



192 Villa Street
 Ponce, Puerto Rico 00730-4875
 Tel. 787-841-7373 Fax 787-841-7313
 Lab ID #: PR00012

Control Number
 149859

Chain of Custody - Drinking Water

COMPANY VI WAPA-STY		SAMPLER NAME: Michael Diaz		ID # Collector:		
SYSTEM NAME IDENTIFICATION:		SAMPLER SIGNATURE: <i>Michael Diaz</i>				
SAMPLING LOCATION: CTECH - Auto Body						
SYSTEM ID: PWSS#	STATION NUMBER	SAMPLING DATE	SAMPLING TIME	WATER SOURCE	TYPE OF SAMPLE	SAMPLE NUMBER
VT000097	N/A	10/19/23	13:59	DRINKING WATER	GRAB	009
CONDUCTIVITY 592 umhos/cm	DISSOLVED OXYGEN N/A mg/L	PH 8.0 S.U.		Temperature 31 °C	Residual chloride 0.31 mg/L	
Parameters to be tested:		Preservatives		Container (size/type/volume)		
LEAD		N/A		2 LITER		
COPPER		N/A		2 LITER		
Sampling witness:		Date / Time: 10/19/23 1:59		Temperature Received:		
Relinquished by: <i>Stuart E. Ad</i>		Date/ Time: 10/19/23 @ 3:50pm		Received by: <i>Don Gregoire</i>		
Relinquished by: <i>Don Gregoire</i>		Date/ Time: 10-20-23 9:35 am		Received by: <i>Ed...</i>		

ORIGINAL

REVISION: 06/2023



192 Villa Street
 Ponce, Puerto Rico 00730-4875
 Tel. 787-841-7373 Fax 787-841-7313
 Lab ID #: PR00012

Control Number
 149860

Chain of Custody - Drinking Water

COMPANY <i>VI MAPA</i>		SAMPLER NAME: <i>RADA SSJUA</i>		ID # Collector		
SYSTEM NAME IDENTIFICATION: <i>PWS ID: VI0000097</i>		SAMPLER SIGNATURE: <i>[Signature]</i>				
SAMPLING LOCATION: <i># 51 RICHMOND ENTRY</i>						
SYSTEM ID: PWSS#	STATION NUMBER	SAMPLING DATE	SAMPLING TIME	WATER SOURCE	TYPE OF SAMPLE	SAMPLE NUMBER
<i>VI000097</i>	<i>N/A</i>	<i>10/19/23</i>	<i>15:25</i>	<i>DRINKING WATER</i>	<i>GRAB</i>	<i>010</i>
CONDUCTIVITY <i>N/A</i> $\mu\text{mhos/cm}$	DISSOLVED OXYGEN <i>N/A</i> mg/L	PH <i>N/A</i> s.u.	Temperature <i>N/A</i> $^{\circ}\text{C}$	Residual chloride <i>N/A</i> mg/L		
Parameters to be tested: <i>Lead</i>		Preservatives <i>N/A</i>		Container (size/type/volume)		
<i>Copper</i>		<i>N/A</i>				
Sampling witness: <i>Don Gregoire</i>		Date / Time: <i>10-19-23 @ 15:25</i>		Temperature Received:		
Relinquished by: <i>[Signature]</i>		Date / Time:		Date / Time:		
Relinquished by: <i>Don Gregoire</i>		Date / Time: <i>10-20-23 9:35 am</i>		Received by: <i>[Signature]</i>		Date / Time: <i>10-20-23 9:3694</i>

ORIGINAL

REVISION: 06/2023

To: BECKTON ENVIRONMENTAL LABORATORIES
 192 VILLA STREET
 PONCE PR 00730-4875

Attn: MRS. AMELIA M. ECHEVARRIA
 Source: BEL 2304408
 PONCE, PR

Project Name: PRDOH
 Facility: ...
 Description: DRINKING WATER - Grab
 Client Ref. #: N/A
 PWSID: N/A

Sample Number: 3918138
 Work Order: 1520-01-25
 Delivery Slip: 2023-13380
 Folder Number: 347053

Remarks:


This report shall not be reproduced, except in full, without the written consent of Environmental Quality Laboratories, Inc.

Laboratory Test Report

Date of Report: 10/24/2023
 Collected By: BECKTON
 Eqlab Rep.: EGARCIA
 Proposal Number: 30474 - 1

Collected Date & Time: 10/19/2023 09:27
 Received Date & Time: 10/23/2023 09:02
 Temperature at Arrival: 3.0 °C

Parameter	Method	Results	Units	DQ	Limits			Analysis			Prep Method		
					MDL	MRL	MCL	Date	Time	By	Date	By	Method
Lead - Total	EPA 200.8	0.00172	mg/L	--	0.00002	0.00100	0.015	10/24/2023	09:48	CRP	10/24/2023	--	Verification



ND = Not Detected MCL = Maximum Contaminant Level EDL = Below Detection Limit DNT = Does Not Ignore MDL = Minimum Detection Limit N/A = Not Applicable
 MRL = Minimum Reporting Level YTRL = Pattern Recognition Level. All results are calculated on a wet weight basis unless otherwise stated. All results relate only to this sample.
 + = Parameter is not accredited under EQLab's PRDOH Certification

ENVIRONMENTAL QUALITY LABORATORIES, INC.
 60 E STREET, MINILLAS INDUSTRIAL PARK, BAYAMON, PR 00959
 PO BOX 11458 SANTURCE, PR 00910-1458 TEL. (787) 288-6420 FAX (787) 288-6465 www.eqlab.com

PRDOH Certified
 EPA ID PR00014

To: BECKTON ENVIRONMENTAL LABORATORIES
 192 VILLA STREET
 PONCE PR 00730-4875

Attn: MRS. AMELLA M. ECHEVARRIA
 Source: BEL 2304409
 PONCE, PR

Project Name: PRDOH
 Facility: ...
 Description: DRINKING WATER - Grab
 Client Ref. #: N/A
 PWSID: N/A

Sample Number: 3918139
 Work Order: 1520-01-25
 Delivery Slip: 2023-13380
 Folder Number: 347053

Remarks:

This report shall not be reproduced, except in full, without the written consent of Environmental Quality Laboratories, Inc.

Laboratory Test Report

Collected Date & Time:	10/19/2023	09:40	Date of Report:	10/24/2023
Received Date & Time:	10/23/2023	09:02	Collected By:	BECKTON
Temperature at Arrival:	3.0 °C		Eqlab Rep.:	EGARCIA
			Proposal Number:	30474 - 1

Parameter	Method	Results	Units	Limits			Analysis			Prep Method			
				DQ	MDL	MRL	MCL	Date	Time	By	Date	By	Method
Lead - Total	EPA 200.8	<MRL	mg/L	J	0.00002	0.00100	0.015	10/24/2023	10:05	CRP	10/24/2023	--	Verification



ND = Not Detected MCL = Maximum Contaminant Level BDL = Below Detection Limit DNI = Does Not Exist MDL = Minimum Detection Limit N/A = Not Applicable
 MRL = Minimum Reporting Level PTEL = Pattern Recognition Level All results are calculated on a weight basis unless otherwise stated. All results relate only to this sample.
 * = Parameter is not accredited under EQLab's PRDOH Certification

ENVIRONMENTAL QUALITY LABORATORIES, INC.
 60 E STREET, MINILLAS INDUSTRIAL PARK, BAYAMON, PR 00959
 PO BOX 11458 SANTURCE, PR 00910-1458 TEL. (787) 288-6420 FAX (787) 288-6465 www.eqlab.com

PRDOH Certified
 EPA ID PR00014

To: BECKTON ENVIRONMENTAL LABORATORIES
192 VILLA STREET
PONCE PR 00730-4875

Attn: MRS. AMELIA M. ECHEVARRIA
Source: BEL 2304410
PONCE, PR

Project Name: PRDOH
Facility: ...
Description: DRINKING WATER - Grab
Client Ref. #: N/A
PWSID: N/A

Sample Number: 3918140
Work Order: 1520-01-25
Delivery Slip: 2023-13380
Folder Number: 347053

Remarks:

This report shall not be reproduced, except in full, without the written consent of Environmental Quality Laboratories, Inc.

Laboratory Test Report

Date of Report: 10/24/2023
Collected By: BECKTON
Eqlab Rep.: EGARCIA
Proposal Number: 30474 - 1

Collected Date & Time: 10/19/2023 09:51
Received Date & Time: 10/23/2023 09:02
Temperature at Arrival: 3.0 °C

Parameter	Method	Results	Units	Limits			Analysis		Prep Method				
				DQ	MDL	MRL	MCL	Date	Time	By	Date	Method	
Lead - Total	EPA 200.8	<MRL	mg/L	J	0.00002	0.00100	0.015	10/24/2023	09:50	CRP	10/24/2023	--	Verification



ND = Not Detected MCL = Maximum Contaminant Level BDL = Below Detection Limit DNI = Does Not Iterate MDL = Minimum Detection Limit N/A = Not Applicable
MRL = Minimum Reporting Level PTRL = Pattern Recognition Level All results are calculated on a wet weight basis unless otherwise stated. All results relate only to this sample.
+ = Parameter is not accredited under EQLab's PRDOH Certification
ENVIRONMENTAL QUALITY LABORATORIES, INC.
60 E STREET, MINILLAS INDUSTRIAL PARK, BAYAMON, PR 00959
PO BOX 11458 SANTURCE, PR 00910-1458 TEL. (787) 288-6420 FAX (787) 288-6465 www.eqlab.com

PRDOH Certified
EPA ID PR00014

To: BECKTON ENVIRONMENTAL LABORATORIES
 192 VILLA STREET
 PONCE PR 00730-4875

Attn: MRS. AMELIA M. ECHEVARRIA
 Source: BEL 2304411
 PONCE, PR

Project Name: PRDOH
 Facility: ...
 Description: DRINKING WATER - Grab
 Client Ref. #: N/A
 PWSID: N/A

Sample Number: 3918141
 Work Order: 1520-01-25
 Delivery Slip: 2023-13380
 Folder Number: 347053

Remarks:

Laboratory Test Report

This report shall not be reproduced, except in full, without the written consent of Environmental Quality Laboratories, Inc.

Date of Report: 10/24/2023
 Collected By: BECKTON
 Eqlab Rep.: EGARCIA
 Proposal Number: 30474 - 1

Collected Date & Time: 10/19/2023 10:17
 Received Date & Time: 10/23/2023 09:02
 Temperature at Arrival: 3.0 °C

Parameter	Method	Results	Units	DQ	Limits			Analysis			Prep Method			
					MDL	MRL	MCL	Time	Date	By	Date	By	Method	
Lead - Total	EPA 200.8	0.00749	mg/L	--	0.00002	0.00100	0.015	09:53	10/24/2023	CRP	--	10/24/2023	--	Verification



PRDOH Certified
 EPA ID PR00014

ND = Not Detected MCL = Maximum Contaminant Level BDL = Below Detection Limit DNI = Does Not Iterate MDL = Minimum Detection Limit N/A = Not Applicable
 MRL = Minimum Reporting Level PTEL = Pattern Recognition Level. All results are calculated on a wet weight basis unless otherwise stated. All results relate only to this sample.
 * = Parameter is not accredited under EQLab's PRDOH Certification
 ENVIRONMENTAL QUALITY LABORATORIES, INC.
 60 E STREET, MINILLAS INDUSTRIAL PARK, BAYAMON, PR 00959
 PO BOX 11458 SANTURCE, PR 00910-1458 TEL: (787) 288-6420 FAX (787) 288-6465 www eqlab.com

To: BECKTON ENVIRONMENTAL LABORATORIES
 192 VILLA STREET
 PONCE PR 00730-4875

Attn: MRS. AMELIA M. ECHEVARRIA
 Source: BEL 2304412
 PONCE, PR

Project Name: PRDOH
 Facility: ... DRINKING WATER - Grab
 Client Ref. #: N/A
 PWSID: N/A

This report shall not be reproduced, except in full, without the written consent of Environmental Quality Laboratories, Inc.

Laboratory Test Report



Sample Number: 3918142
 Work Order: 1520-01-25
 Delivery Slip: 2023-13380
 Folder Number: 347053

Remarks:

Collected Date & Time: 10/19/2023 10:30
 Received Date & Time: 10/23/2023 09:02
 Temperature at Arrival: 3.0 °C

Date of Report: 10/24/2023
 Collected By: BECKTON
 Eqlab Rep.: EGARCIA
 Proposal Number: 30474 - 1

Parameter	Method	Results	Units	DQ	Limits			Analysis			Prep Method		
					MDL	MRL	MCL	Date	Time	By	Date	By	Method
Lead - Total	EPA 200.8	<MRL	mg/L	J	0.00002	0.00100	0.015	10/24/2023	10:08	CRP	10/24/2023	--	Verification



PRDOH Certified
 EPA ID PR00014

ND = Not Detected MCL = Maximum Contaminant Level BDL = Below Detection Limit DNT = Does Not Exceed MDL = Minimum Detection Limit N/A = Not Applicable
 MRL = Minimum Reporting Level PTEL = Pattern Recognition Level All results are calculated on a wet weight basis unless otherwise stated. All results relate only to this sample.
 * = Parameter is not accredited under EQLab's PRDOH Certification

ENVIRONMENTAL QUALITY LABORATORIES, INC.
 60 E STREET, MINILLAS INDUSTRIAL PARK, BAYAMON, PR 00959
 PO BOX 11458 SANTURCE, PR 00910-1458 TEL. (787) 288-6420 FAX (787) 288-6465 www eqlab.com

To:
 BECKTON ENVIRONMENTAL LABORATORIES
 192 VILLA STREET
 PONCE PR 00730-4875

Attn: MRS. AMELIA M. ECHEVARRIA
 Source: BEL 2304413
 PONCE, PR
 Project Name: PRDOH
 Facility: ...
 Description: DRINKING WATER - Grab
 Client Ref. #: N/A
 PWSID: N/A

This report shall not be reproduced, except in full, without the written consent of Environmental Quality Laboratories, Inc.

Laboratory Test Report

Sample Number:	3918143	Collected Date & Time:	10/19/2023 12:26	Date of Report:	10/24/2023
Work Order:	1520-01-25	Received Date & Time:	10/23/2023 09:02	Collected By:	BECKTON
Delivery Slip:	2023-13380	Temperature at Arrival:	3.0 °C	Eqlab Rep.:	EGARCIA
Folder Number:	347053			Proposal Number:	30474 - 1
Remarks:					

Parameter	Method	Results	Units	DQ	Limits			Analysis			Prep Method		
					MDL	MRL	MCL	Date	Time	By	Date	By	Method
Lead - Total	EPA 200.8	0.00469	mg/L	--	0.00002	0.00100	0.015	10/24/2023	10:10	CRP	10/24/2023	--	Verification



ND = Not Detected MCL = Maximum Contaminant Level BDL = Below Detection Limit DNT = Does Not Ignite MDL = Minimum Detection Limit N/A = Not Applicable
 MRL = Minimum Reporting Level PTRL = Pattern Recognition Level. All results are calculated as a wet weight basis unless otherwise stated. All results relate only to this sample.
 + = Parameter is not accredited under EQLab's PRDOH Certification

ENVIRONMENTAL QUALITY LABORATORIES, INC.

60 E STREET, MINILLAS INDUSTRIAL PARK, BAYAMON, PR 00959

PO BOX 11458 SANTURCE, PR 00910-1458 TEL. (787) 288-6420 FAX (787) 288-6465 www.eqlab.com

PRDOH Certified
 EPA ID PR00014

To: BECKTON ENVIRONMENTAL LABORATORIES
 192 VILLA STREET
 PONCE PR 00730-4875

Attn: MRS. AMELIA M. ECHEVARRIA
 Source: BEL 2304414
 PONCE, PR

Project Name: PRDOH
 Facility: ...
 Description: DRINKING WATER - Grab
 Client Ref. #: N/A
 PWSID: N/A

Sample Number: 3918144
 Work Order: 1520-01-25
 Delivery Slip: 2023-13380
 Folder Number: 347053

Remarks:

This report shall not be reproduced, except in full, without the written consent of Environmental Quality Laboratories, Inc.

Laboratory Test Report

Date of Report: 10/24/2023
 Collected By: BECKTON
 Eqlab Rep.: EGARCIA
 Proposal Number: 30474-1

Collected Date & Time: 10/19/2023 12:41
 Received Date & Time: 10/23/2023 09:02
 Temperature at Arrival: 3.0 °C

Parameter	Method	Results	Units	DQ	Limits			Analysis			Prep Method		
					MDL	MRL	MCL	Date	Time	By		Date	By
Lead - Total	EPA 200.8	<MRL	mg/L	J	0.00002	0.00100	0.015	10/24/2023	09:55	CRP	10/24/2023	--	Verification



ND = Not Detected MCL = Maximum Contaminant Level EDL = Below Detection Limit DNI = Does Not Ignite MDL = Minimum Detection Limit N/A = Not Applicable
 MRL = Minimum Reporting Level PTRL = Pattern Recognition Level All results are calculated on a wet weight basis unless otherwise stated. All results relate only to this sample.
 + = Parameter is not accredited under EQLab's PRDOH Certification

ENVIRONMENTAL QUALITY LABORATORIES, INC.

60 E STREET, MINILLAS INDUSTRIAL PARK, BAYAMON, PR 00959
 PO BOX 11458 SANTURCE, PR 00910-1458 TEL. (787) 288-6420 FAX (787) 288-6465 www.eqlab.com

To: BECKTON ENVIRONMENTAL LABORATORIES
 192 VILLA STREET
 PONCE PR 00730-4875

Attn: MRS. AMELIA M. ECHEVARRIA
 Source: BEL 2304415
 PONCE, PR

Project Name: PRDOH
 Facility: ...
 Description: DRINKING WATER - Grab
 Client Ref. #: N/A
 PWSID: N/A

Sample Number: 3918145
 Work Order: 1520-01-25
 Delivery Slip: 2023-13380
 Folder Number: 347053

Remarks:

Laboratory Test Report

This report shall not be reproduced, except in full, without the written consent of Environmental Quality Laboratories, Inc.

Collected Date & Time: 10/19/2023 13:37
 Received Date & Time: 10/23/2023 09:02
 Temperature at Arrival: 3.0 °C

Date of Report: 10/24/2023
 Collected By: BECKTON
 Eqlab Rep.: EGARCIA
 Proposal Number: 30474 - 1

Parameter	Method	Results	Units	Limits			Analysis		Prep Method				
				DQ	MDL	MRL	MCL	Date	Time	By	Date	By	Method
Lead - Total	EPA 200.8	<MRL	mg/L	J	0.00002	0.00100	0.015	10/24/2023	09:57	CRP	10/24/2023	--	Verification



ND - Not Detected MCL - Maximum Contaminant Level BDL - Below Detection Limit DNI - Does Not Ignore MDL - Minimum Detection Limit N/A - Not Applicable
 MRL - Minimum Reporting Level PTRL - Pattern Recognition Level. All results are calculated on a wet weight basis unless otherwise stated. All results relate only to this sample.
 +- Parameter is not accredited under EOLab's PRDOH Certification

ENVIRONMENTAL QUALITY LABORATORIES, INC.
 60 E STREET, MINILLAS INDUSTRIAL PARK, BAYAMON, PR 00959
 PO BOX 11458 SANTURCE, PR 00910-1458 TEL. (787) 288-6420 FAX (787) 288-6465 www.eqlab.com

To: BECKTON ENVIRONMENTAL LABORATORIES
 192 VILLA STREET
 PONCE PR 00730-4875

Attn: MRS. AMELIA M. ECHEVARRIA
 Source: BEL 2304416
 PONCE, PR

Project Name: PRDOH
 Facility: ...
 Description: DRINKING WATER - Grab
 Client Ref. #: N/A
 PWSID: N/A

Sample Number: 3918146
 Work Order: 1520-01-25
 Delivery Slip: 2023-13380
 Folder Number: 347053

Remarks:

Collected Date & Time: 10/19/2023 13:59
 Received Date & Time: 10/23/2023 09:02
 Temperature at Arrival: 3.0 °C

Date of Report: 10/24/2023
 Collected By: BECKTON
 Eqlab Rep.: EGARCIA
 Proposal Number: 30474 - 1

Laboratory Test Report

This report shall not be reproduced, except in full, without the written consent of Environmental Quality Laboratories, Inc.



Parameter	Method	Results	Units	DQ	Limits			Analysis			Prep Method		
					MDL	MRL	MCL	Date	Time	By	Date	By	Method
Lead - Total	EPA 200.8	<MRL	mg/L	J	0.00002	0.00100	0.015	10/24/2023	09:59	CRP	10/24/2023	--	Verification



ND = Not Detected MCL = Maximum Contaminant Level BDL = Below Detection Limit DNI = Does Not Ignite MDL = Minimum Detection Limit N/A = Not Applicable
 MRL = Minimum Reporting Level PTRL = Pattern Recognition Level. All results are calculated on a wet weight basis unless otherwise stated. All results relate only to this sample.
 ++ = Parameter is not accredited under EQLab's PRDOH Certification

ENVIRONMENTAL QUALITY LABORATORIES, INC.
 60 E STREET, MINILLAS INDUSTRIAL PARK, BAYAMON, PR 00959

PO BOX 11458 SANTURCE, PR 00910-1458 TEL. (787) 288-6420 FAX (787) 288-6465 www.eqlab.com

PRDOH Certified
 EPA ID PR00014

To: BECKTON ENVIRONMENTAL LABORATORIES
 192 VILLA STREET
 PONCE PR 00730-4875

Attn: MRS. AMELIA M. ECHEVARRIA
 Source: BEL 2304417
 PONCE, PR

Project Name: PRDOH
 Facility: ...
 Description: DRINKING WATER - Grab
 Client Ref. #: N/A
 PWSID: N/A


Laboratory Test Report

This report shall not be reproduced, except in full, without the written consent of Environmental Quality Laboratories, Inc.



Sample Number:	3918147	Collected Date & Time:	10/19/2023 15:25	Date of Report:	10/24/2023
Work Order:	1520-01-25	Received Date & Time:	10/23/2023 09:02	Collected By:	BECKTON
Delivery Slip:	2023-13380	Temperature at Arrival:	3.0 °C	Eqlab Rep.:	EGARCIA
Folder Number:	347053			Proposal Number:	30474 - 1
Remarks:					

Parameter	Method	Results	Units	DQ	Limits			Analysis			Prep Method		
					MDL	MRL	MCL	Date	Time	By	Date	By	Method
Lead - Total	EPA 200.8	0.00294	mg/L	-	0.00002	0.00100	0.015	10/24/2023	10:01	CRP	10/24/2023	-	Verification



ND = Not Detected MCL = Maximum Contaminant Level BDL = Below Detection Limit DNI = Does Not Inhibit MDL = Minimum Detection Limit N/A = Not Applicable
 MRL = Minimum Reporting Level PTEL = Pattern Recognition Level All results are calculated on a wet weight basis unless otherwise stated. All results relate only to this sample.
 * Parameters not certified under EQLab's PRDOH Certification

ENVIRONMENTAL QUALITY LABORATORIES, INC.
 60 E STREET, MINILLAS INDUSTRIAL PARK, BAYAMON, PR 00959
 PO BOX 11458 SANTURCE, PR 00910-1458 TEL. (787) 288-6420 FAX (787) 288-6465 www eqlab.com