



VIRGIN ISLANDS WATER & POWER AUTHORITY

PR-05-24

St. Croix, Queen Mary Highway, St. Croix

Date: 04/09/2024

ADDENDUM III

Questions, Answers and Clarifications

Questions & Answers

Question #1:

The duct bank schedule on the drawings does not match the quantities listed in the Addendum 1 version of the Bid Form; please clarify whether we are to bid what is in the drawings, or what is on the Bid Form.

Response #1:

Bid the quantities in the Bid Form from Addendum I. The duct banks schedules will be updated in the 'Issue for Construction' drawings.

Question #2:

There is no duct bank section for trench types AA-AA and Z-Z.

Response #2:

Bid Form Line Items 7-Z and 7-AA will not have duct bank sections on the drawings. See Addendum I Bid Form for duct bank descriptions and lengths.


Question #3:

There are several locations where there are unidentified Duct Banks stemming from Manholes and Handholes. Please provide enlarged details for the following structures:


- (E) CMH-8 – STA. 0+00
- (N) EMH-3 & (N) CHH-3 – STA. 20+00-20+27
- (N) EMH-4 & (N) CHH-4 – STA. 31+75-32+00
- (N) EMH-5& (N) CHH-5 – STA. 40+11-40+46

Response #3:

In response to this request please refer to the following (5) enlarged plans. These enlarged plans will be included in the 'Issue for Construction' set of drawings, which will be released after the contract is awarded.




ENLARGED DUCT BANK PLAN (@ MIDLAND EMH-11)




ENLARGED DUCT BANK PLAN (@ EMH3)



ENLARGED DUCT BANK PLAN (@ EMH4)



ENLARGED DUCT BANK PLAN (@ EMH5)



ENLARGED DUCT BANK PLAN (TYPICAL FOR EMH-7&9)