



VIRGIN ISLANDS WATER & POWER AUTHORITY

PR-01-22

DESIGN OF BLACKBEARD'S HILL REPLACEMENT OF POTABLE WATERLINE

ADDENDUM I

1. The selected firm project schedule will be extended from 90 calendar days to 120 calendar days.
2. The selected firm will be responsible for conducting an "alta" survey for the pump station parcel. The selected firm will be required to procure and file all necessary documents for the survey and transfer of parcel from the VI Government to WAPA.
3. Under project information in the RFP it states " this project consists of the design for the installation of 1,300 ft of new 4 in. C-900 pipe", this should be 1,800 ft of new 4 in. C-900 pipe.