



VIRGIN ISLANDS WATER & POWER AUTHORITY
TRANSMISSION & DISTRIBUTION DIVISION

September 29, 2020

PR-06-21 Material Consignment

ADDENDUM II

Addendum II
Issue Date: September 29, 2020

- 1) In review of all the Pad mount specification we have noticed that 7.96 kv and 13.8 kv require for the transformers to be FR3 oil filled however, 14.4kv and 24.9 kv spec do not have FR3 oil filled requirement. Could you please clarify is 24.9Kv and 14.4kv pad mount transformer should be FR3 oil filled as well?

Περίληψη:

All 24.9Kv and 14.4kv pad mount transformer should be filled with FR3 oil.

- 2) Could you please send specifications for the following 2 items:

HEX HEAD BRONZE NUT	283-429-01202
1/2 " BRONZE LOCK WASHER	283-710-56004

Line Item nbr : 283 429 01202
Nbr ELECTRIC UTILITY COMPONENT
NUT, CRIMPIT, SQUEEZON NUT, HEX HEAD BRONZE
1/2" Item ref nbr : 058028
Vendor part nbr : UW25R

Line Item nbr : 283 710 56004
ELECTRIC UTILITY COMPONENT
006 WASHER, LOCK BRONZE
1/2" Item ref nbr : WASHER, LK-BRO 1/2
Vendor part nbr : 1/2"